

- **PIPS (Pond Influent Pump Station)** – The PIPS pump station was upgraded in 2000 and contains six pumps; 4–450 hp and 2–60 hp pumps together with



a standby engine generator set, a surge tank and a soil bed odor control system. Even though this pump station is relatively new



the pumps and equipment as well as the electrical controls and instrumentation will be evaluated for pumping capacity and code compliance. This pump

station serves essentially the entire city and must be highly reliable.